

**TEST REPORT****DATE: 03-03-2021****Page 1 of 1****TEST NUMBER: 0274334**

<b>CLIENT</b>	Lions Floor
---------------	-------------

<b>TEST METHOD CONDUCTED</b>	ASTM F925 (Regular) Standard Test Method for Resistance to Chemicals of Resilient Flooring
------------------------------	--



<b>DESCRIPTION OF TEST SAMPLE</b>	
<b>IDENTIFICATION</b>	Lions Floor Grande Collection
<b>CONSTRUCTION</b>	SPC
<b>BACKING</b>	EVA

**TEST RESULTS**

	<b>5 MINUTE RATINGS</b>	<b>24 HOUR RATINGS</b>
--	-------------------------	------------------------

<b>STAINING AGENT</b>	<b>SURFACE DULLING</b>	<b>SURFACE ATTACK</b>	<b>COLOR CHANGE</b>	<b>SURFACE DULLING</b>	<b>SURFACE ATTACK</b>	<b>COLOR CHANGE</b>
5% Acetic Acid	0	0	0	0	0	0
70% Isopropyl Alcohol	0	0	0	0	0	0
Mineral Oil	0	0	0	0	0	0
5% Sodium Hydroxide	0	0	1	0	0	1
5% Hydrochloric Acid	0	0	0	0	0	0
5% Ammonia	0	0	0	0	0	0
Bleach	0	0	0	0	0	0
5% Phenol	0	0	0	0	0	0
Gasoline	0	0	0	0	0	0
Sulfuric Acid	0	0	0	0	0	0
Kerosene	0	0	0	0	0	0
Olive Oil	0	0	0	0	0	0

<b>RATING KEY</b>
0 - No change (----)
1 - Slight change
2 - Moderate change
3 - Severe change

**APPROVED BY:**

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.