



TEST REPORT

DATE: 02-26-2021

Page 1 of 1

TEST NUMBER: 0274334

CLIENT	Lions Floor
--------	-------------

TEST METHOD CONDUCTED	BS EN 436 Resilient Floor Coverings - Determination of Density
-----------------------	--



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Lions Floor Grande Collection
CONSTRUCTION	SPC
BACKING	EVA

TEST METHOD

Measurements were made to determine the volume and mass of the submitted sample and the calculation was made to show the density.

TEST RESULTS

DENSITY	1.95 grams/cm ³
---------	----------------------------

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.